



CONMARBLE
NATURAL FINISHES



ATTESTATION
CEMHER HYDROPRIMER
Laboratory attestation

A CONMARBLE NATURAL FINISHES SYSTEM · LIME PLASTER

PRODUCT MANUFACTURED BY

CEMHER

Cemher · Spain

DOCUMENT ISSUED BY

Applus Laboratories / LGAI Technological Center S.A. — DANAK-accredited lab reg. 522

Reproduced in full and unaltered. Transmitted by Building Layers by Conmarble as supplier and approved applicator.

[VIEW OUR PROFILE](#)

[CONMARBLE.COM](https://conmarble.com)

BUILDING LAYERS BY CONMARBLE – Tabqat Albunyan Company For Contracting - CR: 7041240065
Showroom Location : Al Urubah Road, Al Olaya, PMV69+7V, City of Riyadh 12333, Saudi Arabia
Email: ahmad@conmarble.com, Insta: @conmarble, Tel: KSA +966 547 888 809 · QA +974 5573 7641

JULY 2026

Attestation

European National Regulations on VOC Emissions

On the 15th of March 2024 Eurofins Product Testing A/S received a sample of a primer with the product name:

HYDROPRIMER

supplied by

KILNHER

The emissions were tested according to the regulations in Germany, France, Belgium and Italy. The test is in accordance with German AgBB (2021) and the guidelines of the DIBt (2010), the German ABG (2019), the French legislation of 2011 on emission classes as specified in decree no 2011-321, the Belgian Royal Decree C-2014/24239 and the Italian CAM DM 23 giugno 2022 n. 256, GURI n. 183 del 6 agosto 2022. Sampling, testing and evaluation were performed according to EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9 and ISO 16000-11 testing standards (see the test report no. 392-2024-00140101_A_EN).

The tested sample complies with the European regulations as mentioned below:

- French VOC Regulation of March and April 2011 showing emission class:
- German ABG/AgBB
- Belgian VOC
- Italian CAM



The tested product complies with referenced European regulations as of 9 October 2024.

09 October 2024



Frederik Foged Haugaard
Analytical Service Manager



Rasmus Verdier
Analytical Service Manager

Tests carried out in collaboration with the  **eurofins** laboratory accredited by DANAK (Reg.nr. 522)

Eurofins certificate N°: 392-2024-00140101_A_EN (7 May 2024)

Sample reception: 15/03/2024

SIMPLIFIED TEST REPORT

Emission of Volatile Organic compounds

N°. 24/32302193-S2

Bellaterra, 8 th May 2024	Product: HYDROPRIMER Batch number: 24F02260206
Manufacturer: Pinturas Kilnher c/ Llanterners, 44- P.I. La Figuera 46970- Alaquas (Valencia)- Spain	

Regulation or protocol:

French VOC Regulation of March and May 2011. Decree of March (DEVL 1101903D) and Arrêté of April 2011(DEVL 1104875A) modified in February 2012 (DEVL1133129A)	
French CMR components. Regulation of April and May 2009 (DEVP 0908633A and DEVP0910046A)	Pass
Italian CAM Edilizia. DM 23 giugno 2022 n.256, GURI n. 183 del 6 agosto 2022	Pass
AgBB/ABG.Ausschuss zur gesundheitlichen Bewertung von Bauprodukten (June 2021)	Pass
Belgian Regulation. Royal decree of May 2015 (C-2014/24239)	Pass
Indoor Air Comfort®. Indoor Air Comfort 9.0 of June 2023	Pass
EU Taxonomy. Regulation (EU) 2020/852 of the European Parliament and of the Council	Pass
LEED v4.1 BETA (February 2024)	Pass

Rble. Mat. Const.

LGAI Technological Center S.A.

Responsible Technician

LGAI Technological Center S.A.

The results specified in this document correspond exclusively to the material received at Applus Laboratories, and tested according to the present indications by the Laboratory Eurofins Product Testing A/S. Sedeskovvej 38; 8464 Galten; Denmark.